481

Pressure reducing valves made of stainless steel with threaded connections

→ Series 481













■ MATERIAL





■ SPECIFICATION



1/2" - 2"





-20°C to +120°C



Inlet pressure: up to 40 bar **Outlet pressure:** 0.5 to 15 bar depending on version

■ SUITABLE FOR

Liquids	neutral and non-neutral	
Air, gases and vapours	neutral and non-neutral	
Potable water cold	up to 40°C	
Potable water hot	up to 85°C	7

■ EXAMPLES OF USE

For the protection of:

- domestic water supply systems
- commercial and industrial plants

against too high supply pressure.

Pressure reducers are used, if within a piping system despite of varying pressures on the inlet side a certain pressure must not be exceeded on the outlet side.

- potable water supply according to DIN 1988
- process water supply in industrial- and building technology
- snow-making equipment
- fire-fighting equipment and sprinkler systems
- shipbuilding industry and offshore plants
- secondary areas in the food-, pharmaceutical- and cosmetics- industries.

■ APPROVALS

DIN-DVGW type examination (up to 80°C)

Type approval ACS

Type approval WRAS (up to 85°C)

Type approval PZH

TR ZU 032/2013 -TR ZU 010/2011

Requirements

DIN DVGW guidelines **DIN EN 1567** DIN 1988

DIN EN ISO 3822 DGR 2014/68/EU

Classification society

DNVGL DNVGL Lloyd's Register EMEA LR EMEA American Bureau of Shipping ABS Bureau Veritas Russian Maritime Register of Shipping **RMRS** Registro Italiano Navale RINA

■ MATERIALS

Component	Material	DIN EN	ASME
Inlet body	Stainless steel	1.4408	CF8M
Outlet body	Stainless steel	1.4408	CF8M
Internal parts	Stainless steel	1.4408	CF8M
	Stainless steel	1.4404	316 L
Spring	Spring steel with anti-rust protection	1.1200	ASTM A228
Strainer	Stainless steel	1.4404	316 L



Series 481 ■ VALVE VERSION

m with diaphragm

High-quality, heat-resistant moulded elastomere, fabric-reinforced diaphragm.

Pressure adjustment by means of non-rising spindle.

Valve insert with balanced single seat valve completely made of stainless steel.

Complete valve insert SP/HP (order code: 481 Insert-DN..-seal) available as replacement part can be exchanged without removing the valve.

Complete valve insert LP (order code: 481 LP Insert-DN..-seal) available as replacement part can be exchanged without removing the valve.

Built-in dirt trap made of stainless steel.

Mesh size:

DN 15 to DN 32 DN 40 and DN 50

0,60 mm 0,75 mm

■ MEDIUM

GF

gaseous and liquid

for water and distilled water, neutral and non-sticking liquids, compressed air and neutral gases; optionally with FPM elastomere seals for non-neutral media i.e. oils, fuels, oil-laden compressed air etc. Not suitable with steam.

■ TYPE OF LIFTING MECHANISM

0

without lifting device

■ OUTLET PRESSURE RANGES

SP	Standard version	Inlet pressure: up to 40 bar	Outlet pressure: from 1 to 8 bar
HP	High-pressure version	Inlet pressure: up to 40 bar	Outlet pressure: from 5 to 15 bar
LP	Low-pressure version	Inlet pressure: up to 25 bar	Outlet pressure: from 0,5 to 2 bar

■ AVAILABLE NOMINAL DIAMETERS AND CONNECTION SIZES

Nominal diameter DN	15	20	25	32	40	50
Inlet	1/2" (15)	3/4" (20)	1" (25)	1 1/4" (32)	1 1/2" (40)	2" (50)
Outlet	1/2" (15)	3/4" (20)	1" (25)	1 1/4" (32)	1 1/2" (40)	2" (50)

■ TYPE OF CONNECTION INLET / OUTLET THREADED CONNECTIONS

BSP-Tm / BSP-Tm	Standard threaded connections	Male thread BSP-T / Male thread BSP-T	DIN EN 10226, ISO 7-1 / DIN EN 10226, ISO 7-1
f/f	Version with female thread available in sizes DN15, DN20 and	Female thread BSP-P / Female thread BSP-P I DN25	DIN EN ISO 228-1 / DIN EN ISO 228-1
NPT-f / NPT-f	Version with female thread available in sizes DN15, DN20 and	Female thread NPT-f / Female thread NPT-f	ANSI B1.20.1 / ANSI B1.20.1

■ SEALS


EPDM	Ethylene propylene diene	Elastomere moulded diaphragm and seals approvals according to drinking water directive	–20°C to +120°C (up to 8 bar outlet pressure) –20°C to +95°C (from 8 bar outlet pressure)
FKM	Fluorocarbon	Elastomere moulded diaphragm and seals	-10°C to +120°C (up to 8 bar outlet pressure) -10°C to +95°C (from 8 bar outlet pressure)



■ NOMINAL DIAMETERS, CONNECTIONS, INSTALLATION DIMENSIONS

Series 481: Connection, insta	llation dime	nsions, ranges of	adjustment				
Connection	DN	15	20	25	32	40	50
Inlet DIN EN 10226	G1	1/2"	3/4"	1"	1 1/4"	1 1/2"	2"
Outlet DIN EN 10226	G2	1/2"	3/4"	1"			
Inlet pressure SP, HP up to	bar	40	40	40	40	40	40
Inlet pressure LP up to	bar	25	25	25	25	25	25
Outlet pressure	bar	0,5 - 2	0,5 - 2	0,5 - 2	0,5 - 2	0,5 - 2	0,5 - 2
		1 - 8	1 - 8	1 - 8	1 - 8	1 - 8	1 - 8
		5 - 15	5 - 15	5 - 15	5 - 15	5 - 15	5 - 15
Installation dimensions	L	142	158	180	193	226	252
in mm	- 1	80	90	100	105	130	140
	I1	85	95	105			
	H (H1)	102 (128¹)	102 (128¹)	130 (150¹)	130 (150¹)	165 (185¹)	165 (185¹)
	H2 (H3)	124 (150 ²)	124(150 ²)	161 (181 ²)	161 (181²)	198 (218²)	198 (218²)
	h	33	33	45	45	70	70
	SW1	30	37	46	52	65	75
	SW2	28	35	43	48	57	68
Pressure gauge connection Outlet pressure	G3	1/4" axial	1/4" axial	1/4" axial	1/4" axial	1/4" axial	1/4" axial
Weight	kg	1,2 (1,5¹)	1,3 (1,6¹)	2,3 (2,8¹)	2,5 (3,0 ¹)	5,2 (5,9¹)	5,7 (6,4¹)
Coefficient of flow K _{vs} ³	m³/h	3	3,5	6,7	7,6	12,5	15

■ MAIN DIMENSIONS, INSTALLATION DIMENSIONS





¹for type 481mGFO-LP ²for type 481mGFO-LP S15 ³The K_{vs} value was determined according to DIN EN 60534-2-3. Instructions on how to determine size and capacity are to be found under section 2.

Series	Valve version	Medium	Lifting device	Outlet pressure	Nominal diameter DN	Connec Inlet	tion type Outlet		Outlet	Seal	Options	Optional: fixed setting	Quar tity
481	m	GF	0	SP	25	BSP-T m			25	EPDM	Manometer 41	3	5
481	m	GF	0	SP	15	f	f	15	15	<i>EPDM</i>	,,		4
481	m	GF	0										
481	m	GF	0										
■ PRO	PERTIES				······································		·····						
S15	Hand wheel (plastic) for t	ool-free se	tting of setpre	essure ¹								
S17	Supply with n	nanometers s	uitable for t	the valve finish	1								
S71	Preliminary s		ection again	st manipulatio	on of the								
or nomir	nal diameters DN		utlet pressur	e ranges LP and	d SP								
■ OPT	IONS						•••••						
GOX		aterials inclu		ns by employr nd grease free									
			estion										
P01	Oil- and grea	se-free produ	ICHOH										
FE	Oil- and grease Setting and s	ealing											
P01 FE CER	Setting and s	ealing APPROVALS	S		2)		C05				SP 3, 3-A,),		
FE ■ CER	Setting and s	ealing APPROVALS ficate acc. D	S		2)		C05	Manufactur Please indic	er certificati	ion of certif	ficate:		
FE CER	Setting and s TIFICATES / A Factory certifications and setting a	ealing APPROVALS ficate acc. D te acc. DIN E certificate ac	S JIN EN 1020 N 10204 3.1				C05	Manufactur Please indic ATEX evalu	er certificati cate descript	ion of certil	ficate:		
FE CER™ CO1 CO2	Factory certifications (pressure retifications)	ealing APPROVALS ficate acc. DIN E certificate ac aining part) ndividual insp	N 10204 3.1	(WPZ 3.1)			C05 C06 C10	Manufactur Please indic ATEX evalu Certificate (Certification	er certificaticate descript ation acc. to of oil- and grand of the process of the	2014/34/EU ease free p	ficate:	lly for gase- fic materials	
© CERT CO1 CO2 CO3 CO4	Factory certification Material test (pressure retification). TÜV/DEKRA i (TÜV/DEKRA-	ealing APPROVALS ficate acc. DIN E certificate ac aining part) ndividual insp APZ)	N 10204 3.1 cc. DIN EN 1	(WPZ 3.1) 10204 3.1 (MPZ			C05 C06 C10	Manufactur Please indic ATEX evalu Certificate (Certification	er certificaticate descript ation acc. to of oil- and grand of the process of the	2014/34/EU ease free p	ficate: J production access especia	lly for gase- fic materials	
© CERT CO1 CO2 CO3 CO4	Factory certification Material test (pressure ret. TÜV/DEKRA-IUSSIONS / A	ealing APPROVALS ficate acc. DIN E certificate ac aining part) ndividual insp APZ) CCREDITAT	N 10204 3.1 cc. DIN EN 1	(WPZ 3.1) 10204 3.1 (MPZ . EN 10204 3.2	Z 3.1)		C05 C06 C10 C11	Manufactur Please indic ATEX evalu Certificate (Certification ous oxygen	er certificaticate descript ation acc. to of oil- and grant of the procapplications	2014/34/EU 2014/34/EU rease free p duction pro s by employ	ficate: J production access especia	lly for gase- fic materials	
© CERT CO1 CO2 CO3 CO4	Factory certical Material test (pressure retical TÜV/DEKRA-ITÜV/DE	ealing APPROVALS ficate acc. DIN E certificate ac aining part) ndividual insp APZ) CCREDITAT nination acc.	N 10204 3.1 cc. DIN EN 1 pection acc	(WPZ 3.1) 10204 3.1 (MPZ . EN 10204 3.2 re 2014/68/EU	Z 3.1)		C05 C06 C10 C11 AK1	Manufactur Please indic ATEX evalu Certificate (Certification ous oxygen	er certificaticate descript ation acc. to of oil- and grant of the procapplications	2014/34/EU rease free p duction pro s by employ	ficate: J production preess especia ment of speci	lly for gase- fic materials	
© CERT CO1 CO2 CO3 CO4 AA1	Factory certical Material test (pressure retical TÜV/DEKRA-ITÜV/DE	ealing APPROVALS ficate acc. DIN E certificate ac aining part) ndividual insp APZ) CCREDITAT nination acc. cate/declara	N 10204 3.1 cc. DIN EN 1 pection acc	(WPZ 3.1) 10204 3.1 (MPZ . EN 10204 3.2	Z 3.1)		C05 C06 C10 C11 AK1	Manufactur Please indic ATEX evalu Certificate (Certification ous oxygen	er certificaticate descript ation acc. to of oil- and grant of the procapplications	2014/34/EU rease free p duction pro s by employ	ficate: J production preess especia ment of speci	lly for gase- fic materials	
© CERT CO1 CO2 CO3 CO4	Factory certification Test certification Material test (pressure retification) TÜV/DEKRA-ITÜV/DEKRA	ealing APPROVALS ficate acc. DIN E certificate ac aining part) ndividual insp APZ) CCREDITAT nination acc. cate/declararking of the verein des Gas	N 10204 3.1 cc. DIN EN 1 pection acc	(WPZ 3.1) 10204 3.1 (MPZ . EN 10204 3.2 re 2014/68/EU	Z 3.1)		C05 C06 C10 C11 AK1 AK2	Manufactur Please indic ATEX evalu Certificate (Certification ous oxygen DNV-GL (D Lloyd's Reg	er certificaticate descript ation acc. to of oil- and grand of the procapplications NVGL) type	ease free publication of certification of certification prospective by employ approval	ficate: J production preess especia ment of speci	fic materials	
© CERTCO CO1 CO2 CO3 CO4 AA1 AA4	Factory certification of the second of the s	ealing APPROVALS ficate acc. DIN E certificate ac aining part) ndividual insp APZ) CCREDITAT nination acc. cate/declara rking of the v cerein des Gas	N 10204 3.1 cc. DIN EN 1 pection acc TONS to Directive tion with payalve s- und Was	(WPZ 3.1) 10204 3.1 (MPZ . EN 10204 3.2 re 2014/68/EU	Z 3.1) e valve /GW		C05 C06 C10 C11 AK1 AK2 AK3	Manufactur Please indic ATEX evalu Certificate (Certification ous oxygen DNV-GL (D Lloyd's Reg American E	er certificaticate descript ation acc. to of oil- and grand of the procapplications NVGL) type	2014/34/EU rease free p duction pro s by employ approval //pe approv	production Decess especial Decess especial Decess especial Decess especial Decess especial Decess especial	fic materials	
© CERT CO1 CO2 CO3 CO4 AA1 AA4 AB1	Factory certification of the second of the s	ealing APPROVALS ficate acc. DIN E certificate ac aining part) ndividual insp APZ) CCREDITAT mination acc. cate/declara rking of the v cerein des Gas il	N 10204 3.1 cc. DIN EN 1 pection acc TONS to Directive tion with payalve s- und Was visory sche	(WPZ 3.1) 10204 3.1 (MPZ . EN 10204 3.2 ve 2014/68/EU assport for the	Z 3.1) e valve /GW pe		C05 C06 C10 C11 AK1 AK2 AK3 AK4	Manufactur Please indic ATEX evalu Certificate (Certification ous oxygen DNV-GL (D Lloyd's Reg American E	er certificaticate descript ation acc. to of oil- and gran of the procapplications NVGL) type gister (LR) type aritime Regi	ease free provided the period of certification of certification and the period of certification and the period of certification of certification and the period of certification	production Decess especial Decess especial Decess especial Decess especial Decess especial Decess especial	fic materials	
© CERTCO CO1 CO2 CO3 CO4 — ADM AA1 AA4 AB1 AB2	Factory certification of the second of the s	ealing APPROVALS ficate acc. DIN E certificate ac aining part) ndividual insp APZ) CCREDITAT mination acc. cate/declara rking of the v cerein des Gas il	N 10204 3.1 cc. DIN EN 1 pection acc TONS to Directive tion with payalve s- und Was visory sche	(WPZ 3.1) 10204 3.1 (MPZ . EN 10204 3.2 ve 2014/68/EU assport for the serfaches, DV	Z 3.1) e valve /GW pe		C05 C06 C10 C11 AK1 AK2 AK3 AK4	Manufactur Please indic ATEX evalu Certificate (Certification ous oxygen DNV-GL (D Lloyd's Reg American E Bureau Ver Russian Matype appro	er certificaticate descript ation acc. to of oil- and gr n of the procapplications NVGL) type gister (LR) ty Bureau of SI ritas (BV) ty aritime Regional	ease free publication of certification of certification of certification and certification properties by employ approval approval pe approval pe approval ster of Shi	ficate: J production process especia ment of specification ral as symmetric symm	oval	

■ ENQUIRY

Copy and send to: order@goetze-armaturen.de.


Order form easily to be found online under the section for each series.



Series 481:

Dimensioning by pressure loss on the outlet pressure side

Flow chart water



Dimensioning by flow velocity

For Liquids

With \hat{N} help of the chart you can determine the nominal diameter (DN) for a given flow volume V (\hat{m}^3 /h). According to DVGW-guidelines (DIN 1988) a flow velocity of 2 m/s in domestic water supply systems should not be exceeded.

For compressed air and other gaseous media:

The usual flow velocity for compressed air is 10 - 20 m/s. For gaseous media the flow volume V should always be shown in actual cubic meters/hour. If the flow volume is given in standard cubic meters, these should be converted into actual cubic meters before using the diagram.

$$V\left(m^{3}/h\right) = \frac{V_{\text{Norm}}\left(Nm^{3}/h\right)}{p_{\text{absolut}}\left(bar\right)} = \frac{V_{\text{Norm}}}{p_{\ddot{\upsilon}} + 1}$$

Actual cubic meters are based on the prevailing pressure of the medium on the outlet side of the pressure reducer.

