



AUTOMATIC PUMP AND STEAM TRAP APST DN 40 – DN 50

DESCRIPTION

The ADCAMAT APST (Automatic Pump and Steam Trap) fabricated in carbon steel or stainless steel is specially recommended where a stall condition may occur due to poor steam trap condensate discharge, caused by temporary insufficient differential pressure.

The equipment has the features of a float steam trap combined with a pressure operated pump in the same unit.

Whenever the steam trap function is not enough to drain the condensate, the pump function is activated (using external steam pressure), before water logging may occur, lifting the condensate to the condensate return system, avoiding water hammer and consequent noise and equipment damage, corrosion, unstable temperature control, etc.



OPERATION

During the start-up, the pump ball float mechanism is in the closed position (bottom), the motive steam valve is closed, and the vent line is open.

The steam trap mechanism is, at this stage, modulating the condensate flow as it increases, but if the differential pressure decreases and the condensate level goes up, the pump mechanism starts to work and, at the upper level, the steam motive valve opens, closing at the same time the vent valve and, consequently, pressing the condensate to the outlet through the steam trap mechanism.

After the pump cycle, if the necessary differential pressure is available again, the steam trap will restart the operation. Otherwise, the pump function will remain active.

| MAIN | | | | | | | | |
|---------------|---|------------------------|-----------------------|--|--|--|--|--|
| FEATURES: | No electric requirements. No NPSH issues. | | | | | | | |
| | Operation under vacuum conditions. | | | | | | | |
| | Closed loop system, no motive or flash steam is | lost. | | | | | | |
| OPTIONS: | Stainless steel construction. | | | | | | | |
| | Level gauge. | | | | | | | |
| USE: | Drain and lift condensate from heat exchangers | | | | | | | |
| AVAILABLE | (among others). | | | | | | | |
| MODELS: | ADCAMAT APST-S – Carbon steel construction. | | | | | | | |
| | ADCAMAT APST-SS – Stainless steel construction. | | | | | | | |
| | (Carbon steel version is sandblasted, metalized | and black painted). | | | | | | |
| 01750 | DN 40 x 40; DN 50 x 50; 11/2 x 11/2"; 2" x 2". | | | | | | | |
| SIZES: | Flanged EN1092-1 PN16. | | | | | | | |
| CONNECTIONS: | Female screwed ISO 7/1 Rp (BS21) (Threaded | flanges). | | | | | | |
| | Others on request. | | | | | | | |
| INSTALLATION: | Horizontal installation. | | | | | | | |
| | See IMI – Installation and maintenance instructions. | CE MARKING – GROUP 2 (| PED – European Direct | | | | | |
| | | PN16 | Category | | | | | |
| MOTIVE GAS: | Saturated steam. | All sizes | 2 (CE marked) | | | | | |
| | | | | | | | | |

VALSTEAM ДДСД

We reserve the right to change the design and material of this product without notice.








| APPLICATION LIMITS | | | | | | | | | |
|--------------------------|-----------|--|--|--|--|--|--|--|--|
| Minimum density | 0,80 kg/L | | | | | | | | |
| Maximum viscosity | 5 ºEngler | | | | | | | | |
| Maximum motive pressure | 10 bar | | | | | | | | |
| Minimum motive pressure | 0,5 bar | | | | | | | | |
| Pump discharge per cycle | 22 L | | | | | | | | |

| | APST-S | | APST-SS | | | | |
|----------------|-------------------|---------------|---------|-------------------|---------------|--|--|
| PN16 | Pressure (bar) | Temp. (⁰C) | | Pressure (bar) | Temp. (⁰C) | | |
| | 16 | 50 | | 16 | 50 | | |
| | 14 | 100 | PN16 | 16 | 100 | | |
| | 13 | 195 | | 13 | 195 | | |
| | 12 | 250 | | 12 | 250 | | |
| ANSI 150 lb | 16 | 50 | ANSI | 16 | 50 | | |
| | 13 | 195 | 150 lb | 13 | 195 | | |

Min. operating temp.: -10 °C; Design code: AD-Merkblatt. * Rating according to EN 1092-1:2018.










| | DIMENSIONS (mm) | | | | | | | | | | | | | | |
|------------|-----------------|-----|-----|----|-----|-----|-----|-----|-----|-----|----|----|-----|--------------|-------------|
| SIZE DN | A * | в | с | C1 | D | Е | F | G | н | I | J | L | М | WGT. (kg) | VOL. (L) |
| 40 X 40 | 883 | 721 | 212 | 97 | 542 | 356 | 200 | 210 | 512 | 490 | 17 | 18 | 250 | 81 | 45 |
| 50 X 50 | 910 | 726 | 212 | 97 | 542 | 356 | 200 | 210 | 512 | 490 | 17 | 18 | 250 | 84 | 45 |


* A – with welding neck EN 1092-1 flanges. Dimensions are different if threaded flanges are requested.

VALSTEAM JDCJ










| | MATERIALS | | | | | | | | | |
|-----------|-----------------------------------|--|--|--|--|--|--|--|--|--|
| POS. № | DESIGNATION | MATERIAL APST-S | MATERIAL APST-SS | | | | | | | |
| 1 | Pump body | P265GH / 1.0425 ; P235GH / 1.0345 ; S235JR / 1.0038 | AISI 316 / 1.4401; AISI 316L / 1.4404 | | | | | | | |
| 2 | Cover | GJS-400-15 / 0.7040 | CF8M / 1.4408 | | | | | | | |
| 3 | * Cover gasket | Non asbestos | Non asbestos | | | | | | | |
| 3.1 | * Outlet cover gasket | Non asbestos | Non asbestos | | | | | | | |
| 4 | * Inlet valve / Seat assembly | Stainless steel | Stainless steel | | | | | | | |
| 5 | *Exhaust valve / Seat assembly | Stainless steel | Stainless steel | | | | | | | |
| 6 | Internal mechanism | Stainless steel | Stainless steel | | | | | | | |
| 7 | *Float | Stainless steel | Stainless steel | | | | | | | |
| 8 | * Spring assembly (2 pieces) | INCONEL | INCONEL | | | | | | | |
| 9.1 | * RD40 outlet check valve | CF8M / 1.4408 | CF8M / 1.4408 | | | | | | | |
| 9.2 | * RD40 Inlet check valve | CF8M / 1.4408 | CF8M / 1.4408 | | | | | | | |
| 10 | Bolts | Steel 8.8 | A2-70 | | | | | | | |
| 11 | ** PN16 EN 1092-1 flanges | P250GH / 1.0460 | AISI 316 / 1.4401 | | | | | | | |
| 12 | * Float trap mechanism | loat trap mechanism Stainless steel | | | | | | | | |
| 13 | * Steam trap float | Stainless steel | Stainless steel | | | | | | | |
| 14 | Level gauge cocks | Bronze / Stainless steel | Stainless steel | | | | | | | |
| 15 | Tube glass | Borosilicate | Borosilicate | | | | | | | |

* Available spare parts;

** Welding neck EN 1092-1:2018 flanges. Threaded flanges under request.

VALSTEAM ДДСД







CAPACITY MULTIPLYING FACTORS FOR OTHER FILLING HEADS

| Pump size | Filling head (mm) | | | | | | | |
|-------------|-------------------|-----|-----|------|--|--|--|--|
| Pullip Size | 150 | 300 | 600 | 900 | | | | |
| All | 0,7 | 1 | 1,2 | 1,35 | | | | |

Filling heads measured from the bottom of the receiver centre line of the heat exchanger to the top of the cover mechanism. Consult factory for receiver sizing.





Chart 1 (based on liquid specific gravity 0,9 - 1,0).

| APST STEAM TRAP FLOW RATE CAPACITY (kg/h) | | | | | | | | | | | |
|---|---------|-----------------------------|------|------|------|-------|-------|-------|-------|-------|-------|
| MODEL | SIZE | DIFFERENTIAL PRESSURE (bar) | | | | | | | | | |
| MODEL | DN | 0,1 | 0,3 | 0,5 | 0,7 | 1 | 1,5 | 2 | 4,5 | 7 | 10 |
| APST-10 | 40 x 40 | 900 | 1500 | 1900 | 2300 | 2700 | 3100 | 3600 | 5000 | 6900 | 8100 |
| APST-10 | 50 x 50 | 1800 | 3000 | 3900 | 4450 | 5000 | 6100 | 7100 | 10000 | 13750 | 16000 |
| APST-4,5 | 50 x 50 | 2400 | 5900 | 7550 | 9050 | 11000 | 14000 | 15500 | 22500 | - | _ |

Important: motive pressure should not exceed the maximum rated differential pressure at any circumstances.

e.g. APST-10, the motive pressure ≤10 barg. If the APST-4,5, the motive pressure ≤4,5 barg.

Lower steam trap discharge capacity available on request.

VALSTEAM ДДСД





SIZING AND INSTALLATION

SIZING OF THE SYSTEM

The discharge capacity of the pump is a function of:

1.Condensate load (kg/h).

2. The pressure of operating medium (steam, compressed air or other gases).

3. The total lift or back pressure the pump will have to exhaust against. This includes the change in fluid level elevation after the pump (0.0981 bar/m of lift), plus pressure in the return piping, plus the pressure drop in bar caused by pipe friction, plus any other system component pressure drop the pump exhaust will have to overcome.

5.Maximum steam pressure on the process equipment (heat exchanger, for example) (barg).

6.Minimum temperature of the medium to be heated (°C).

7.Controlled temperature of medium to be heated (°C).

Calculation methods: see IS 9.085 E.

RECEIVER

A receiver is recommended to temporarily hold the liquid and prevent any flooding of the equipment, while the pump is in the pumping cycle. A length of pipe of large diameter can be used.

INSTALLATION – Closed loop system

Fig.1 shows a typical installation example of ADCAMAT APST (Automatic Pump & Steam Trap) applied to a large capacity skid mounted ADCATHERM PWHU (Packaged Water Heating Unit).




Fig.1

S – Steam inlet C – Condensate return CW – Cold water inlet HW – Hot water delivery

